

SECTION 08300 DITEC DS9 MANUAL SLIDING DOOR SYSTEMS.

1. GENERAL

1.01 Summary

- A. Work included: Furnishing and installing factory fabricated and finished manual sliding door system.
- B. Related Work: [Insert applicable section including]
 - 1. Section 07900 Caulking
 - 2. Section 08400 Entrances and Storefronts
 - 3. Section 08710 Finished Hardware
 - 4. Section 08800 Glazing
 - 5. Section 16120 Electrical (Static Electric Grounding)

1.02 Submittals

- A. Product Data: Provide manufacturer's product and complete installation data for all materials in this specification.
- B. Shop Drawings: Show profiles, joining method, location of components, anchorage details, adjacent construction interface and dimensions.
- C. Samples: Sized to adequately represent material
- D. Contract Closeout: Submit the Manufacturer's warranty and performance certification (if applicable)
- E. Installation Guide: Provide written installation and operating manuals and/or installation recommendations.

1.03 Quality Assurance

- A. Installation and maintenance shall be performed by an authorized dealer and in strict compliance with the manufacturer's recommendations.
- B. Installing dealer shall provide factory authorized and trained service professionals 24 hours a day, seven days a week. The installing and servicing dealer shall be a certified member of AAADM (American Association of Automatic Door Manufacturers).

1.04 Product Handling

- A. All materials shall arrive in the manufacturers original sealed, labelled containers.
- B. Store materials in a dry, protected, well-vented area. Report any damaged material immediately to the delivering carrier and note such damage on the carrier's freight bill of lading.
- C. Remove and dispose of all protective materials after installation.

1.05 Job Condition

A. Verify that other trades are complete before installing the manual sliding door system.



- B Mounting surfaces shall be plumb, straight and secure; substrates shall be proper dimension and material.
- C Refer to the construction documents, shop drawings and manufacturer's installation instructions.
- D Coordinate installation with the glass and glazing.
- E Observe all appropriate OSHA safety guidelines for this work.
- 1.06 Warranty/Guarantee
- A Manufacturer's Standard Limited Warranty: Warranted materials shall be free of defect in material and workmanship for three years after installation
- 2. PRODUCTS
- 2.01 Manufacturer: ENTREMATIC Group AB

Entrematic Canada Inc. 221A Racco Parkway Vaughan, Ontario, L4J 8X9 Phone: 1-877-348-6837 Entrematic USA Inc. 1900 Airport Rd Monroe, NC, 28110 Phone: 1-866-901-4284

2.02 Manual Sliding Door System

- A. <u>Manual Door System:</u> Shall be DITEC DS9 Manual Sliding Door System. The system shall consist of sliding aluminum door(s), frames and header, completely engineered, manufactured and assembled by ENTREMATIC. All components shall be factory assembled, adjusted and tested.
- B. <u>Sliding Aluminum Doors:</u> Provide through bolted door units (narrow or medium stile) to dimension heights and widths with intermediate rail(s) and corresponding glazing stops to accommodate ½" (6mm) or ½" (16mm) glass thickness. Sliding door(s) shall be sized to prevent pinch points at meeting stiles.
- C. <u>Door Operation:</u> Shall be either the 2 panel, 3 panel and 4 panel basic package or the 3 panel or 6 panel telescopic package. Custom engineered door packages are also available. All systems are available without floor tracks.
- D. <u>Aluminum Frame & Extrusions:</u> Shall be a minimum .125" (3mm) in integral structural sections. The frame shall be 4 ½" (114mm) deep x 1 ¾" wide (44mm) section with basic package or 6" deep (152mm) with telescopic package. The bi-part transom package shall contain one vertical transom tube, specify if desired. Transoms are available for ¼" (6mm) glazing.
- E. <u>Aluminum Extrusion Finish:</u> Standard anodized finish shall be Clear or Dark Bronze. Special anodized, painted and clad finishes are available upon request. Specify type and color.
- F. <u>Pivot Assemblies</u> for trackless (SX) panel applications shall allow the sliding panels to swing outward for emergency egress without the need of a lower pivot support. Active sliding panels to be at full open position before breakaway actuation.



- G. <u>Header Case:</u> Shall be 4½" wide x 3 5/8" high (114 mm x 92mm) extruded aluminum. The header shall encompass the door track and anti-riser guide. The extruded aluminum cover shall have a continuous self-locking hinge which allows it to open flush with the top of the header.
- H. <u>Door Hanger Wheels:</u> Shall be 2½" (64mm) diameter nylon wheels with stainless steel lifetime lubricated ball bearing centres. The sliding door(s) shall be held on the track by 2" (51mm) antiriser wheels and supported by a factory adjusted cantilever support & pivot assembly. The door height shall have an adjustment as required by field conditions. All door height and ant-rise adjustments shall be fully accessible with the hinge cover in the "open" position
- I. <u>Architectural Hardware:</u> Shall be supplied with painted finish. Standard color of finish shall be silver or flat black. Recessed door pulls shall be provided for easy movement of doors. Surface mounted "D" shaped pull handles are optional. Positive latching handles are also optional. Stops shall be provided in the header to limit door slide travel.
- J. <u>Static Electric Grounding:</u> Specify; if applicable all manual sliding doors shall be provided with static electric grounding.
- K. <u>Accessories:</u> The lead stile of the sliding door(s) shall be provided with double brush-pile or vinyl weather stripping options.

2.03 Operating Conditions

A. All manual sliding door system components shall operate between -4F (-20C) and +120F (50C) in all climate conditions.

3 EXECUTION

3.01 Inspection

A. Verify that the manual sliding door system installation will not disrupt other trades. The door installer shall verify that the installation area is dry, clean and free of foreign matter. Check asbuilt conditions and verify the manufacturer's details for accuracy to fit the wall assembly prior to fabrication. Report in writing to the Contractor conditions that are detrimental to the proper functioning of the intensive care unit door package. Installation shall proceed once unsatisfactory conditions have been corrected in accordance to the manufacturer's recommendations.

3.02 Installation of Manual Sliding Door System

- A. Installation shall be by an installer approved and trained by the manufacturer in strict accordance with the manufacturer's instructions and fire marshal's listing requirements.
- B. Comply with the manual sliding door system manufacturer's recommendations and/or installation guide when installing the door system. Set all units plumb, level and true.
- C. Provide all fasteners required for installation of the manual sliding door system.
- D. Adjustment and Cleaning: After repeated operation of the completed installation, re-adjust doors for optimum operating condition and safety. Clean all metal surfaces promptly after installation.

END SECTION 08300



All the rights concerning this material are the exclusive property of Entrematic Group AB.

Although the contents of this publication have been drawn up with the greatest care, Entrematic Group AB cannot be held responsible in any way for any damage caused by mistakes or omissions. We reserve the fight to make changes without prior notice.